

**BOARD MEMBERS**

Tina Certain  
Diyonne McGraw  
Sarah Rockwell, Ph.D.  
Leannetta McNealy, Ph.D.  
Kay Abbitt



District Office  
620 East University Avenue  
Gainesville, Florida  
32601-5498

www.sbac.edu  
(352) 955-7300  
Fax (844) 269-9018

**SUPERINTENDENT OF SCHOOLS**

Shane L. Andrew, Superintendent

**An 'A-rated' District**

*Mission Statement: We are committed to the success of every student!*

DATE: February 3, 2023  
TO: All Prospective Proposers  
IFB NO.: 23-23, UPS Backup Units (E-Rate)  
RE: ADDENDUM NO. 01

The following addendum is in response to requests for in-person equipment inspection asked for by prospective Bidders.

The information contained herein shall become part of the contract awarded by the District for the specified services. Bidder shall indicate acceptance of the information contained in this addendum by signing in the spaces provided below. The signed addendum shall be included with Bid response.

ADDENDUM NO. 01


1. Please find revised form of proposal attached. 2. APC unit SMT2200R2X167 was listed as preferred unit. Unit referenced shall be replaced with SMT2200RM2UNC as preferred unit and basis for “or equal” comparison.
2. Q: The bid requested a preinstalled Network Management Card. These are best utilized with APC’s management software Ecostruxure IT Expert. Would you still like this included in responses even though it is not E-Rate eligible?  
A: No. Please bid equipment only.
3. Q: Are evaluation units required?  
A: Evaluation units may be requested after bid opening from apparent low bidder, in the event that low bidder has submitted an “or equal”.
4. Q: Is the awarded vendor installing the unit?  
A: No.
5. Q: Is there a loading dock?  
A: Yes. The delivery address that will be provided on the purchase order will have a loading dock.
6. Q: Are you buying 70 units at one time?  
A: The intent of the District is to purchase all 70 units at one time. Funding of this purchase is contingent upon the Letter of Commitment from FCC/SLD.

7. Q: It appears the SMT2200R2X167 does not have internal batteries and only uses external battery packs. What runtime is required?

A: Please see statement 1 on this addendum.

**ALL OTHER TERMS, CONDITIONS, AND PROVISIONS OF IFB 23-23 REMAIN UNCHANGED AND IN FULL FORCE AND EFFECT.**

Sincerely,



Jeffrey C. Garcia  
Purchasing Manager

cc: Purchasing File

**IFB 23-23**

**ADDENDUM NO. 01: RECEIVED AND ACCEPTED**

**COMPANY:** \_\_\_\_\_  
**NAME:** \_\_\_\_\_  
**TITLE:** \_\_\_\_\_  
**SIGNATURE:** \_\_\_\_\_  
**DATE:** \_\_\_\_ / \_\_\_\_ / \_\_\_\_

ATTACHMENT C  
FORM OF PROPOSAL  
IFB 23-23 UPS BACKUP UNITS

**Instructions:** Bidder shall submit unit price and manufacturer product information for the specified item as listed. Unit prices shall be inclusive of product, packaging, delivery, labor, insurance, profit, and all other services that are necessary for the proper execution and performance of contract. No other charges or surcharges shall be applicable to this contract unless specifically permitted herein. Unless as otherwise permitted and expressly stated herein, prices offered shall be firm and fixed for the term of contract.

Should there be any variance of proposed “or equal” product from specified product, a written request for approval must be submitted to the Purchasing Department, accompanied by manufacturer published literature and technical specifications, as stated in paragraph 8 of attachment B. Bidder is advised to carefully examine product specifications and exercise their own judgment as to quality and performance of products required prior to submitting Bid.

Item #	Description	Est. Qty.	U/M	Unit Cost	Extend Amount
01	APC Smart UPS #SMT2200RM2UNC; <i>Or Approved Equivalent</i>	70	Each	\$	\$
“Or Equal” Product Bid:					
Manufacturer	Product/Brand Name	Mfg. Product Number	Case Pack	N/A Pkg. Size	N/A Dilution Rate

AWARD TOTAL	\$
Delivery shall normally be made within _____ calendar days of receipt of order.	

The following salient features of the above specified UPS reflect the minimum characteristics of any acceptable “Or Equal” equipment. Please place a check mark next to each “minimum characteristic” your submission complies with. Failure to complete this checklist may result in the rejection of Bid.

- Warranty:** 3 year warranty excluding battery. 2 year warranty on the battery itself.
- Network Capability:** Installed network management card to remotely manage the UPS via SNMP and web interface; management software included. Support e-mail notifications via SMTP.
- Power Capacity:** 2200 VA
- Miscellaneous:**
  - Rack mountable.
  - Six (6) outlets.
  - AC 120 V.