


BOARD MEMBERS

Tina Certain
Diyonne McGraw
Sarah Rockwell, Ph.D.
Leannetta McNealy, Ph.D.
Kay Abbitt



District Office
620 East University Avenue
Gainesville, Florida
32601-5498

www.sbac.edu
(352) 955-7300

Fax (844) 269-9018

SUPERINTENDENT OF SCHOOLS

Shane L. Andrew, Superintendent

An 'A-rated' District

Mission Statement: We are committed to the success of every student!

DATE: February 7, 2023
TO: All Prospective Proposers
IFB NO.: 23-23, UPS Backup Units (E-Rate)
RE: ADDENDUM NO. 02

The information contained herein shall become part of the contract awarded by the District for the specified services. Bidder shall indicate acceptance of the information contained in this addendum by signing in the spaces provided below. The signed addendum shall be included with Bid response.

ADDENDUM NO. 02

1. Q: The part number provided says the UPS is 120V/230V input and 120V output, in the specs they are requesting a UPS that is 120V input and output. Are we to quote a UPS that provides 120V input and 120V output?

A: This question was addressed in addendum #1. The item referenced in the specs was incorrect. Please refer to addendum #1 for information regarding the correct unit.

2. Q: Nema Code for 2000VA and 2200VA UPS systems use a 5-20 plug. Can we confirm that 20-amp plugs with the UPS is okay?

A: Yes.

ALL OTHER TERMS, CONDITIONS, AND PROVISIONS OF IFB 23-23 REMAIN UNCHANGED AND IN FULL FORCE AND EFFECT.

Sincerely,

Jeffrey C. Garcia
Purchasing Manager

cc: Purchasing File

IFB 23-23

ADDENDUM NO. 02: RECEIVED AND ACCEPTED

COMPANY: _____
NAME: _____
TITLE: _____
SIGNATURE: _____
DATE: ____/____/____